

3745-89-11

Certified laboratories for the "Long Term 2 Enhanced Surface Water Treatment Rule".

- (A) Cryptosporidium. Systems shall have Cryptosporidium samples analyzed in accordance with procedures identified in rule 3745-81-27 of the Administrative Code by a laboratory that is certified by the United States environmental protection agency, the "National Environmental Laboratory Accreditation Program (NELAP)," or by another state to perform the required analyses.
- (B) E. coli. Systems shall have E. coli samples analyzed in accordance with procedures identified in rule 3745-81-27 of the Administrative Code by a laboratory that is certified by the United States environmental protection agency or the "National Environmental Laboratory Accreditation Program (NELAP)" for E. coli analysis in accordance with 40 C.F.R. 141.74(a)(1), April 2013, provided that the laboratory obtains acceptable results on a source water proficiency test sample.
- (C) Turbidity. Measurements of turbidity shall be made in accordance with paragraph (C)(3) of rule 3745-81-27 of the Administrative Code.

[Comment: The 40 CFR 141.74 refers to "Analytical and monitoring requirements" published on May 31, 2013. A copy of this code may be obtained from the "U.S. Government Bookstore" toll-free at (866) 512-1800 or <http://bookstore.gpo.gov>, or from "Ohio EPA, Lazarus Government Center, 50 West Town Street, Suite 700, Columbus, OH 43215," (614) 644-2752. The code is available for review at "Ohio EPA, Lazarus Government Center, 50 West Town Street, Suite 700, Columbus, OH 43215."]

Replaces: 3745-89-11

Effective:

Five Year Review (FYR) Dates:

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 6109.04
Rule Amplifies: 6109.03, 6109.04
Prior Effective Dates: 1/8/10