

3745-91-09

Iron and manganese treatment.

(A) New community water systems shall provide treatment for removal of [the following](#):

- (1) Iron to meet the secondary maximum contaminant level ([SMCL](#)) set forth in rule 3745-82-02 of the Administrative Code when the level of iron in water entering the water plant exceeds the ~~secondary maximum contaminant level;~~ ~~and~~ [SMCL](#).
- (2) Manganese to meet the ~~secondary maximum contaminant level~~ [SMCL](#) set forth in rule 3745-82-02 of the Administrative Code when the level of manganese in water entering the water plant exceeds the ~~secondary maximum contaminant level~~ [SMCL](#).

(B) Existing community water systems, which develop a new source, or change a source shall provide treatment for [removal of the following](#):

- (1) Iron [to meet the SMCL set forth in rule 3745-82-02 of the Administrative Code](#), if the level of iron at the entry point to the distribution system increases and exceeds the ~~secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code;~~ ~~and~~ [SMCL](#).
- (2) Manganese [to meet the SMCL in rule 3745-82-02 of the Administrative Code](#), if the level of manganese at the entry point to the distribution system increases and exceeds the ~~secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code~~ [SMCL](#).