

\*\*\* DRAFT – NOT FOR FILING \*\*\*

3745-91-10 Drinking water source protection plan.

- (A) A public water system that receives approval, after the effective date of this rule, from the director for a public water system well, provides water to a political subdivision of Ohio and serves a minimum of 250 people shall develop or update a previously agency endorsed drinking water source protection plan (aka- wellhead protection plan).
- (B) The plan shall be submitted to the agency within one year of the date of the director's action approving the public water system well.
- (C) The plan shall contain contingency, contaminant source control strategy, education and emergency response components, address the need for an early warning ground water monitoring program and an implementation schedule.
- (D) A public water system is exempt from the requirements of this rule if it has an agency endorsed drinking water source protection plan and any increased pumping or the location of the well(s) will not change the boundaries of the previously endorsed inner management zone or drinking water source protection area.