

3745-18-20 **Clinton County emission limits.**

No owner or operator of any coal-fired steam generating unit shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

R.C. 119.032 review dates: 10/28/2005 and 10/28/2010

CERTIFIED ELECTRONICALLY

Certification

10/28/2005

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03
Rule Amplifies: 3704.02
Prior Effective Dates: 12/28/79