

Defiance County emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Dinner Bell Foods" (OEPA premise number 0320010009) or any subsequent owner or operator of the "Dinner Bell Foods" facility located on West High Street, Defiance, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 8 (OEPA source number B001) to exceed a maximum of 1.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (C) The "Toledo Edison Company" (OEPA premise number 0320010006) or any subsequent owner or operator of the "Toledo Edison Company" facility located on Carpenter Road, Defiance, Ohio shall not cause or permit the emission of sulfur dioxide from turbine numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.

R.C. 119.032 review dates: 10/28/2005 and 10/28/2010

CERTIFIED ELECTRONICALLY

Certification

10/28/2005

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03
Rule Amplifies: 3704.02
Prior Effective Dates: 12/28/79