

3745-18-19

Clermont county emission limits.

No owner or operator of any coal-fired steam generating unit in Clermont county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Cincinnati Gas and Electric Company, W. C. Beckjord Station" (OEPA premise number 1813100008) or any subsequent owner or operator of the "Cincinnati Gas and Electric Company, W. C. Beckjord Station," New Richmond, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Boiler numbers 1 through 4 (OEPA source numbers B001 through B004); a maximum of 1.84 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(2) Boiler numbers 5 and 6 (OEPA source numbers B005 and B006); a maximum of 7.19 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(3) Turbine numbers 7 through 10 (OEPA source numbers B007 through B010); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.~~

~~(C) The "Ford Motor Company" (OEPA premise number 1813000137) or any subsequent owner or operator of the "Ford Motor Company," Batavia, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1, 2, and 3 (OEPA source numbers B001 through B003) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input.~~