

3745-18-33

Gallia county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Gallia county, unless otherwise specified ~~below~~ in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Ohio Valley Electric Corporation, Kyger Creek Station" (OEPA premise number 0627000003) or any subsequent owner or operator of the "Ohio Valley Electric Corporation, Kyger Creek Station" ~~facility~~ located in Cheshire, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 ~~through to~~ 5 (OEPA source numbers B001 ~~through to~~ B005) to exceed a maximum of 8.2 pounds of sulfur dioxide per MM Btu actual heat input from each stack.
- (C) [Reserved.]
- (D) The "~~Ohio Power Company/Ohio Electric Company~~, General James ~~A. M.~~ M. Gavin Power Plant" (OEPA premise numbers ~~0627010045~~0627010056) or any subsequent owner or operator of the "~~Ohio Power Company/Ohio Electric Company~~, General James ~~A. M.~~ M. Gavin Power Plant" ~~facility~~ located in Cheshire, Ohio shall not cause or permit the emission of sulfur dioxide from unit one main boiler and unit two main boiler (OEPA source numbers B003 and B004) to exceed a maximum of 7.41 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.