

*** DRAFT - NOT YET FILED ***

3745-18-55

Madison county emission limits.

No owner or operator of any coal-fired steam generating unit in Madison county shall cause or permit the emission of sulfur dioxide from any source to exceed the maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed the maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "London Correctional Institute" (OEPA premise number 0149010062) or any subsequent owner or operator of the "London Correctional Institute" facility located in London, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~