

3745-18-79

**Scioto county emission limits.**

No owner or operator of any coal-fired steam generating unit in Scioto county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 6.9 pounds of sulfur dioxide per MM Btu actual heat input.

Replaces: 3745-18-79  
Effective: 02/16/2017  
Five Year Review (FYR) Dates: 11/29/2021

CERTIFIED ELECTRONICALLY

---

Certification

02/06/2017

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3704.03(E)  
Rule Amplifies: 3704.03(A), 3704.03(E)  
Prior Effective Dates: 12/28/79, 8/24/81, 1/23/06, 2/17/11