

3745-18-86

Union county emission limits.

No owner or operator of any coal-fired steam generating unit in Union county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Ohio Reformatory for Women" (OEPA premise number 0180010017) or any subsequent owner or operator of the "Ohio Reformatory for Women" facility located at 1479 Collins avenue, Marysville, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1, 3, and 4 (OEPA source numbers B001 through B003) to exceed a maximum of 6.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~