

3745-91-06

Requirements for supporting information.

The supporting information required by this rule may vary depending on the type and complexity of the project and shall, at a minimum, include:

- (A) An explanation of the project and its basis of design, and such other information relevant to approval of plans that may not be fully evident from the plan drawings and specifications;
- (B) A copy of the results of any required chemical, bacteriological, radiological, or other analyses performed on the raw or finished water;
- (C) Information as to the capacity and long-term adequacy of the source of supply; and
- (D) If the plans include a new well as a source of water, the following additional materials shall be submitted:
 - (1) A well site acceptance letter signed by a representative of the district office;
 - (2) A copy of a deed, easement, or other legal instrument showing that the owner has control of lands sufficient to provide isolation as approved in the well site acceptance letter; and
 - (3) A copy of the log of the well, and a copy of the results of the pumping tests performed on the well. Test pumping and sampling for chemical and radiological analyses are required unless waived by the director.
- (E) A capability assurance plan, if required by Chapter 3745-87 of the Administrative Code.

Five Year Review (FYR) Dates: 10/26/2015 and 10/26/2020

CERTIFIED ELECTRONICALLY

Certification

10/26/2015

Date

Promulgated Under: 119.03
Statutory Authority: 6109.04
Rule Amplifies: 6109.03, 6109.04, 6109.07
Prior Effective Dates: 11/26/80, 01/01/02