

3745-18-11

Athens county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Athens county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) The "Ohio University-Lausche Heating Plant" (OEPA premise number 0605010016) or any subsequent owner or operator of the "Ohio University-Lausche Heating Plant, Factory Street, Athens, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler ~~numbers~~number ~~136641~~, 136642, ~~and 136643~~ (OEPA source ~~numbers~~number ~~B043~~, B042 ~~and B041~~) to exceed a maximum of 4.7 pounds of sulfur dioxide per MM Btu actual heat input from ~~each~~the boiler.