

*** DRAFT - NOT YET FILED ***

3745-18-26

Defiance county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Defiance county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) The "Richland Substation Peaker Facility" (OEPA premise number 0320010006) or any subsequent owner or operator of the "Richland Substation Peaker Facility"~~facility located on~~, Carpenter ~~road~~Rd, Defiance, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine numbers 1 to 3 (OEPA source numbers B001 to B003) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.