

3745-18-33

Gallia county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Gallia county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Ohio Valley Electric Corporation, Kyger Creek Station" (OEPA premise number 0627000003) or any subsequent owner or operator of the "Ohio Valley Electric Corporation, Kyger Creek Station," ~~located in~~ [5758 State Route 7 North](#), Cheshire, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 to 5 (OEPA source numbers B001 to B005) to exceed a maximum of 8.2 pounds of sulfur dioxide per MM Btu actual heat input from each stack.
- (C) [Reserved.]
- (D) The "General James M. Gavin Power Plant" (OEPA premise numbers 0627010056) or any subsequent owner or operator of the "General James M. Gavin Power Plant," ~~located in~~ [7397 N St Rt #7](#), Cheshire, Ohio" shall not cause or permit the emission of sulfur dioxide from unit one main boiler and unit two main boiler (OEPA source numbers B003 and B004) to exceed a maximum of 7.41 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.