

3745-18-61

Miami county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Miami county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.2 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Piqua Municipal Power System" (OEPA premise number 0855100041) or any subsequent owner or operator of the "Piqua Municipal Power System"~~facility~~
~~located at~~ 919 South Main street, Piqua, Ohio" shall not cause or permit the emission of sulfur dioxide from CT number 8 oil-fired boiler (OEPA source number B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.