

3745-18-63

Montgomery county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Montgomery county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 1.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) [Reserved.]
- (D) [Reserved.]
- (E) [Reserved.]
- (F) [Reserved.]
- (G) [Reserved.]
- (H) [Reserved.]
- (I) The "~~DP&L~~ Tait Generating Station" (OEPA premise number 0857043333) or any subsequent owner or operator of the "~~DP&L~~ Tait Generating Station, 2101 Arbor Blvd., Moraine, Ohio" shall not cause or permit the emission of sulfur dioxide from oil-fired IC units T-1 to T-4 (OEPA source numbers B507 to B510) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each unit.
- (J) [Reserved.]
- (K) [Reserved.]
- (L) [Reserved.]
- (M) The "~~Dayton Power and Light Company~~, O.H. Hutchings ~~CT~~Station" (OEPA premise number 0857780013) or any subsequent owner or operator of the "~~Dayton Power and Light Company~~, O.H. Hutchings ~~CT~~ Station, 9200 Chautauqua Road, Miamisburg, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine number 7 (OEPA source number B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (N) The "~~Dayton Power and Light Company~~, Yankee Street ~~Generating Station~~" (OEPA

premise number 0857810015) or any subsequent owner or operator of the "~~Dayton Power and Light Company~~, Yankee Street ~~Generating Station~~, 9975 Yankee ~~Road~~Street, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine numbers y-1 to y-7 (OEPA source numbers B001 to B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.

(O) [Reserved.]

(P) [Reserved.]

(Q) [Reserved.]

(R) [Reserved.]

(S) [Reserved.]

(T) The "Tate & Lyle, ~~Incorporated~~Dayton" (OEPA premise number 0857041333) or any subsequent owner or operator of the "Tate & Lyle, ~~Incorporated~~Dayton, 5600 Brentlinger Drive, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from unit numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 0.8 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.