

3745-18-84

**Trumbull county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit in Trumbull county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 5.4 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) [Reserved.]
- (D) The "Niles ~~Plant~~Combustion Turbine (Niles Power, LLC)" (OEPA premise number 0278060023) or any subsequent owner or operator of the "Niles ~~Plant~~Combustion Turbine (Niles Power, LLC)" ~~facility located at~~, 1047 Belmont ~~avenue~~Avenue, Niles, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine A (OEPA source number B004) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (E) [Reserved.]
- (F) [Reserved.]
- (G) [Reserved.]
- (H) [Reserved.]
- (I) [Reserved.]
- (J) The "ArcelorMittal Warren" (OEPA premise number 0278000648) or any subsequent owner or operator of the "ArcelorMittal Warren" ~~facility located on~~, Main street, Warren, Ohio" shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Boiler number 1 (OEPA source number B010); a maximum of 3.9 pounds of sulfur dioxide per MM Btu actual heat input.
  - (2) Boiler number 2 (OEPA source number B011); a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input.