

3745-18-85

Tuscarawas county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Tuscarawas county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) [Reserved.]
- (D) [Reserved.]
- (E) The "Dover Municipal Light Plant" (OEPA premise number 0679010146) or any subsequent owner or operator of the "Dover Municipal Light Plant"~~facility located at~~ 303 East Broadway, Dover, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number 4 (OEPA source number B004) to exceed a maximum of 4.6 pounds of sulfur dioxide per MM Btu actual heat input.