

3745-18-92

**Williams county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit in Williams county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Stryker Substation Peaker" (OEPA premise number 0386000006) or any subsequent owner or operator of the "Stryker Substation Peaker"~~facility located on~~, 101 Railroad street, Stryker, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine W251G (OEPA source number P002) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input.
- (C) The "Bryan Municipal ~~Light and Water~~ Utilities" (OEPA premise number 0386010200) or any subsequent owner or operator of the "Bryan Municipal ~~Light and Water~~ Utilities"~~facility located at~~, 225 South ~~Emmitt street~~Emmet Street, Bryan, Ohio" shall not cause or permit the emission of sulfur dioxide from gas turbine numbers 6 and GT-1 (OEPA source numbers P004 and P005) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.